



Government Of West Bengal
Office Of The Deputy Director
West Bengal Fire & Emergency Services
Station Feeder Road, P.O & P.S Siliguri,
District: Darjeeling, Pin - 734005

Memo no.:IND/WB/FES/20182019/46198

Date: 28-05-2021

From:
Divisional Fire Officer
North Zone, HQ Wing,
West Bengal Fire & Emergency Services

To: Dinodia Educational Society
Tenzing Norgy Road, Dagapur, P.O./P.S.- Pradhan Nagar, Dist- Darjeeling , Pin- 734003.

Sub: Issuance of Renewal of Fire Safety Certificate for the G+2 Storied Educational Building under group Educational at above noted address.

This is in reference to your application no. 0125191210500042 dated 17-03-2021 regarding the Issuance of Renewal of Fire Safety Certificate for the G+2 Storied Educational Building under group Educational at above noted address.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

Subject to fulfillment following conditions

- 1) Good housekeeping to be maintained both inside as well as outside the building
- 2) Floor Numbers as well as directional signs of escape routes to be prominently displayed
- 3) Fire Notice for evacuation and fire fighting to be prepared to display at all vulnerable places in the building
- 4) The occupants, employees and security staff to be made well-conversant about the installed fire safety and protection measures for their use in exigencies
- 5) Mock practice and fire evacuation drills to be organized for the regular periodical performance in accordance to the National Building Code - Part IV.
- 6) Electrical wiring of the afore said building should be checked and maintenance to be done by an licensed electrician.
- 7) Trained Firemen and Fire Officers in the form of prescribed crew to be maintained for round the clock safety of the

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the "Verification of Digitally Signed Document" link and keying in the Unique Number : 0125191210500042.

Page : 1

Powered By For secure paperless solutions
Please visit www.emsigner.com

G. D. GOENKA PUBLIC SCHOOL
AFF. NO. 2430123

Principal

establishment.

8) Mock practice and fire evacuation drills to be organized for the regular periodical performance in accordance to the National Building Code - Part IV.

9) All Exit & Entrance should be free from obstruction.

This certificate is valid for 3 year u/r 18 of WBFS (Fire Prevention and Safety) Rules,2003 and renewable after 3 year from date of issue failing which this shall be revoked automatically.


G. D. GOENKA PUBLIC SCHOOL
AFF. NO. 2430123
Principal

Signature valid

Digitally signed by DEWAN
LEPCHA
Date: 2021.05.23 13:51:16 IST

Divisional Fire Officer
West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL - adistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191210500042

Page : 2